



800 Cushman Street
Fairbanks, AK 99701

Telephone (907)459-6747
Fax (907)452-5913

MOORE STREET SENIOR APARTMENTS PARKING LOT IMPROVEMENTS
PROJECT NO. ITB-26-15
ADDENDUM NO. 2

July 20, 2026

Request for Proposal No.: ITB-26-15
Proposal Submittal Date and Time: 2:00 P.M., July 22, 2022

The following changes, clarifications, and or additions are hereby made to the MOORE STREET SENIOR APARTMENTS PARKING LOT IMPROVEMENTS, PROJECT NO. ITB-26-15

Changes to the Plans:

- **Sheet R1 : Modifications to Senior Center Roof Drain.**
- **Pen & Ink Modification – Sheet C1 – Estimate of Quantities – Modify Item 608.2001.0000 Steel Bollard, Fixed to 606.2001.0000 Steel Bollard, Fixed**

Changes to the Bid Documents:

- **Pen & Ink Modification – Page 12, BID SCHEDULE – Modify Item 608.2001.0000 Steel Bollard, Fixed to 606.2001.0000 Steel Bollard, Fixed**
- **Pen & Ink Modification – Page 46, PART IV - TECHNICAL & SPECIAL PROVISIONS, SECTION 609 CURBING 609-2.01 Delete "Section 550, City of Fairbanks Concrete Mix"**

Response to Questions:

- 1. Steel Bollards (Qty 18) – Powder coating not required. Finish shall be (2) coats of Safety Yellow Paint.**
- 2. Roof Drain System Modifications**
 - Existing Roof Gutter from Point A to Point D to remain as is.
 - Start modifications from existing Downspout and install new roof gutter, securely attached to building, to a point between Point D and Point E as shown on Sheet R1 Modifications.
 - Snow guards (snow stops) will not be required as part of this project.
 - Heat Trace is intended to rest freely in the gutter.

ADDENDUM NO. 2

This Addendum must be acknowledged in the space provided on the bid schedule sheet or by manually signing this amendment sheet and submitting it prior to the bid opening.

All other terms, conditions, and specifications of the original Invitation for Bid remain unchanged.

CITY OF FAIRBANKS




Jeff Whipple
Project Manager

ACKNOWLEDGMENT

Signature

Date

Company Name



Roof Gutter From PT A to PT D to remain.

<table border="1"> <tr> <td>DATE</td> <td>REVISION</td> <td>BY</td> </tr> <tr> <td> </td> <td> </td> <td> </td> </tr> </table>			DATE	REVISION	BY				SCALE: NONE DESIGNED: DRAWN: WKR CHECKED: JW DATE: 	APPROVED CITY ENGINEER DATE 	 MOORE ST. SENIOR APARTMENTS PARKING LOT IMPROVEMENTS	ROOF DRAIN CITY OF FAIRBANKS, ALASKA Engineering Department Project ITB-26-15	 07/10/26 R1 OF 2 SHEETS
DATE	REVISION	BY											