



# A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210  
Phone (207) 784-5354 website [www.allaboratory.com](http://www.allaboratory.com)

## Laboratory Report

Academy Hill School  
585 Depot St  
Wilton, ME 04294

Date Printed: 05/05/2022  
Work Order #: 2203-03921  
Client Job #: 615  
Date Received: 03/29/2022  
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the \* symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

**A & L Laboratory:**  
*Identified by ME in Analyst Column*  
155 Center Street, Auburn, Maine 04210  
[www.allaboratory.com](http://www.allaboratory.com)

**Granite State Analytical Services LLC:**  
*Identified by NH in Analyst Column*  
22 Manchester Road, Derry, NH 03038  
[www.granitestateanalytical.com](http://www.granitestateanalytical.com)

### ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

### SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche  
Laboratory Director

A & L Laboratory: Accreditations: Maine ME00021, New Hampshire 2501, Maine Radon Registration ID # SPC20  
Granite State Analytical Services, LLC: Accreditations: New Hampshire 1015; Maine NH00003;  
Massachusetts M-NH0003; Rhode Island 101513; Vermont VT-101507  
Nashoba Analytical, LLC: Accreditations: Massachusetts M-MA1118



# A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210  
 Phone (207) 784-5354 website www.allaboratory.com

## CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 05/05/2022  
 CLIENT NAME: Academy Hill School

CLIENT ADDRESS: 585 Depot St  
 Wilton, ME 04294

METHOD: EPA 200.8  
 EPA ACTION LEVEL: 15 ppb  
 MAINE GUIDELINE: 4 ppb  
 REPORTING LIMIT: 1 ppb

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

DATE AND TIME RECEIVED: 03/29/2022 01:05PM  
 ANALYSIS PACKAGE: Maine Schools-Lead  
 RECEIPT TEMPERATURE: 16° CELSIUS  
 CLIENT JOB #: 615

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2203-03921-001	bottle fill outside office	I	DWF	03/26/2022 06:05AM	6.4	ppb			DR-NH	05/04/2022 10:20PM
2203-03921-002	nurse's room sink	I	OT	03/26/2022 06:05AM	16.9	ppb			DR-NH	05/04/2022 10:23PM
2203-03921-003	sink room 211	I	OT	03/26/2022 06:12AM	83.3	ppb			DR-NH	05/04/2022 10:26PM
2203-03921-004	bottle fill upstairs	I	DWF	03/26/2022 06:05AM	<1	ppb			DR-NH	05/04/2022 10:29PM
2203-03921-005	bottle fill ground floor	I	DWF	03/26/2022 06:06AM	14.2	ppb			DR-NH	05/04/2022 10:32PM
2203-03921-006	kitchen kettle #1	I	KF	03/26/2022 06:06AM	22.2	ppb			DR-NH	05/04/2022 10:35PM
2203-03921-007	kitchen kettle #2	I	KF	03/26/2022 06:06AM	8.6	ppb			DR-NH	05/04/2022 10:37PM
2203-03921-008	kitchen food prep sink	I	KF	03/26/2022 06:06AM	6.1	ppb			DR-NH	05/04/2022 10:40PM
2203-03921-009	kitchen dish prep sink	I	KF	03/26/2022 06:06AM	5.7	ppb			DR-NH	05/04/2022 10:55PM

Rebecca L. Labranche  
 Laboratory Director