

A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

Laboratory Report

Cape Cod Hill Elem School 516 Cape Cod Hill Rd New Sharon, ME 04955 Date Printed: 05/05/2022
Work Order #: 2203-03917
Client Job #: 612
Date Received: 03/29/2022
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:

Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:

Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. None
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample.
 These are indicated under the DQ Flags Column on your report and listed here if necessary: Data Qualifier (DQ) Flags: None

SAMPLE STATE SPECIFIC NOTES:

 The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: None

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche Laboratory Director



A&L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED:

05/05/2022

CLIENT NAME:

Cape Cod Hill Elem School

CLIENT ADDRESS:

516 Cape Cod Hill Rd

New Sharon, ME 04955

METHOD:

EPA 200.8

EPA ACTION LEVEL: MAINE GUIDELINE: REPORTING LIMIT: 15 ppb 4 ppb 1 ppb Legend

Lead Above 4 ppb Lead Above 15 ppb **⊕**⊗

DATE AND TIME RECEIVED: ANALYSIS PACKAGE:

03/29/2022 01:00PM Maine Schools-Lead

RECEIPT TEMPERATURE: 14° CELSIUS

CLIENT JOB #: 612

| Sample ID # | Location | Sample Type | Outlet Type | Date - Time Water Sampled | Result | Test Units | Pass /Fail | DQ Flag | Analyst | Date - Time Analyzed |
|----------------|--------------------------------------|----------------|----------------|------------------------------|--------|------------|---------------|------------|---------|-------------------------|
| 2203-03917-001 | kitchen kettle | ı | KF | 03/26/2022 09:03AM | 8.7 | ppb | 1 | | DR-NH | 05/04/2022 07:15PM |
| 2203-03917-002 | kitchen sink #1 | 1 | KF | 03/26/2022 09:02AM | 2.1 | ppb | | | DR-NH | 05/04/2022 07:18PM |
| 2203-03917-003 | kitchen sink #2 | ı | KF | 03/26/2022 09:02AM | <1 | ppb | | | DR-NH | 05/04/2022 07:21PM |
| 2203-03917-004 | sink #1 art room | 1 | OT | 03/26/2022 08:43AM | <1 | ppb | | | DR-NH | 05/04/2022 07:24PM |
| 2203-03917-005 | sink #2 art room | 1 | OT | 03/26/2022 08:44AM | <1 | ppb | | | DR-NH | 05/04/2022 07:27PM |
| 2203-03917-006 | sink nurse's room | 1 | OT | 03/26/2022 08:43AM | 6.0 | ppb | 1 | | DR-NH | 05/04/2022 07:30PM |
| 2203-03917-007 | sink teachers room | ı | OT | 03/26/2022 08:30AM | 1.6 | ppb | | | DR-NH | 05/04/2022 07:33PM |
| 2203-03917-008 | Bottle fill outside elevator | 1 | DWF | 03/26/2022 08:59AM | <1 | ppb | | | DR-NH | 05/04/2022 07:35PM |
| 2203-03917-009 | sink room 101 | 1 | OT | 03/26/2022 08:40AM | <1 | ppb | | | DR-NH | 05/04/2022 07:47PM |
| 2203-03917-010 | sink room 104 | ι | OT | 03/26/2022 08:40AM | 5.4 | ppb | 1 | | DR-NH | 05/04/2022 07:50PM |
| 2203-03917-011 | sink room 102 | 1 | OT | 03/26/2022 08:40AM | 3.2 | ppb | | | DR-NH | 05/04/2022 07:59PM |
| 2203-03917-012 | sink room 103 | 1 | OT | 03/26/2022 08:41AM | 6.7 | ppb | 1 | | DR-NH | 05/04/2022 08:02PM |
| 2203-03917-013 | sink room 105 | 1 | 0T | 03/26/2022 08:41AM | 3.2 | ppb | | | DR-NH | 05/04/2022 08:05PM |
| 2203-03917-014 | sink room 106 | 1 | OT | 03/26/2022 08:42AM | 5.2 | ppb | 1 | | DR-NH | 05/04/2022 08:08PM |
| 2203-03917-015 | sink #1 outside elevator upstairs | 1 | ОТ | 03/26/2022 08:48AM | <1 | ppb | | | DR-NH | 05/04/2022 08:11PM |
| 2203-03917-016 | sink #2 outside elevator upstairs | ı | 0Т | 03/26/2022 08:48AM | <1 | ppb | | | DR-NH | 05/04/2022 08:14PM |
| 2203-03917-017 | sink room 204 | 1 | ОТ | 03/26/2022 08:57AM | 13.9 | ppb | 1 | | DR-NH | 05/04/2022 08:22PM |
| 2203-03917-018 | sink room 202 | 1 | OT | 03/26/2022 08:57AM | 7.8 | ppb | 1 | | DR-NH | 05/04/2022 08:25PM |
| 2203-03917-019 | sink room 203 | ı | OT | 03/26/2022 08:48AM | 13.8 | ppb | 1 | | DR-NH | 05/04/2022 08:28PM |
| 2203-03917-020 | sink room 205 | 1 | ОТ | 03/26/2022 08:58AM | 15.8 | ppb | \otimes | | DR-NH | 05/04/2022 08:31PM |
| 2203-03917-021 | sink room 206 | 1 | OT | 03/26/2022 08:58AM | 11.3 | ppb | | | DR-NH | 05/04/2022 08:40PM |

Rebecca L. Labranche Laboratory Director

ZIILL

Page 2 of 2