

A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

Laboratory Report

Cascade Brook School 162 Learning Ln Farmington, ME 04938

Date Printed: Work Order #:

05/05/2022 2203-03924

Client Job #: Date Received: 610 03/29/2022

Sample collected in:

Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:

Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratorv.com

Granite State Analytical Services LLC:

Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. None
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample.
 These are indicated under the DQ Flags Column on your report and listed here if necessary: Data Qualifier (DQ) Flags: None

SAMPLE STATE SPECIFIC NOTES:

 The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: None

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210 website www.allaboratory.com Phone (207) 784-5354

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED:

05/05/2022

CLIENT NAME:

Cascade Brook School

CLIENT ADDRESS:

162 Learning Ln

Farmington, ME 04938

METHOD: **EPA ACTION LEVEL:** **EPA 200.8**

MAINE GUIDELINE: REPORTING LIMIT: 15 ppb 4 ppb

1 ppb

Legend

Lead Above 4 ppb Lead Above 15 ppb

1 8

DATE AND TIME RECEIVED: **ANALYSIS PACKAGE:**

03/29/2022 01:00PM Maine Schools-Lead

RECEIPT TEMPERATURE: 16° CELSIUS

CLIENT JOB #:

610

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2203-03924-001	bottle fill outside room 137	ı	DWF	03/26/2022 07:57AM	2.1	ppb			DR-NH	05/04/2022 10:58PM
2203-03924-002	bottle fill outside room 255	× 1 1	DWF	03/26/2022 07:59AM	2.2	ppb			DR-NH	05/04/2022 11:01PM
2203-03924-003	kitchen kettle	1	KF	03/26/2022 07:55AM	25.6	ppb	\otimes		DR-NH	05/04/2022 11:04PM
2203-03924-004	kitchen 3-bay sink	- 1	KF	03/26/2022 07:55AM	29.3	ppb	8		DR-NH	05/04/2022 11:07PM
2203-03924-005	kitchen hand sink	1	KF	03/26/2022 07:55AM	174	ppb	\otimes		DG-NH	05/04/2022 08:35PM
2203-03924-006	kitchen sink	1	KF	03/26/2022 07:55AM	11.3	ppb	1		DR-NH	05/04/2022 11:10PM
2203-03924-007	sink room 112	1	OT	03/26/2022 07:57AM	4.2	ppb	1		DR-NH	05/04/2022 11:13PM
2203-03924-008	sink room 117	1	OT	03/26/2022 07:57AM	9.3	ppb	1		DR-NH	05/04/2022 11:16PM
2203-03924-009	sink room 122	1	OT	03/26/2022 07:58AM	3.1	ppb			DR-NH	05/04/2022 11:28PM
2203-03924-010	sink room 250	1	OT	03/26/2022 08:02AM	15.2	ppb	\otimes		DR-NH	05/04/2022 11:30PM
2203-03924-011	sink room 253	1	ОТ	03/26/2022 08:00AM	12.6	ppb	1		DR-NH	05/04/2022 11:39PM
2203-03924-012	sink room 254	1	OT	03/26/2022 08:03AM	6.0	ppb	1		DR-NH	05/04/2022 11:42PM
2203-03924-013	sink room 255	1	OT	03/26/2022 08:01AM	14.9	ppb			DR-NH	05/04/2022 11:45PM
2203-03924-014	sink room 240	1	OT	03/26/2022 07:59AM	10.4	ppb	1		DR-NH	05/04/2022 11:48PM
2203-03924-015	sink room 244	1	OT	03/26/2022 08:01AM	13.4	ppb	1		DR-NH	05/04/2022 11:51PM
2203-03924-016	sink room 245	1	OT	03/26/2022 08:01AM	14.7	ppb	1		DR-NH	05/04/2022 11:54PM
2203-03924-017	sink room 260	1	OT	03/26/2022 08:02AM	19.4	ppb	8		DR-NH	05/05/2022 12:03AM
2203-03924-018	sink room 261	1	ОТ	03/26/2022 08:00AM	12.1	ppb	1		DR-NH	05/05/2022 12:06AM
2203-03924-019	sink room 204	1	OT	03/26/2022 08:03AM	15.4	ppb	8		DR-NH	05/05/2022 12:09AM
2203-03924-020	sink room 264	1	OT	03/26/2022 08:01AM	17.6	ppb	8		DR-NH	05/05/2022 12:12AM
2203-03924-021	sink room 265	I	OT	03/26/2022 08:00AM	17.1	ppb	\otimes		DR-NH	05/05/2022 12:20AM

Rebecca L. Labranche **Laboratory Director**

ZIZKL