



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

Laboratory Report

Mt Blue High School
129 Seamon Rd
Farmington, ME 04938

Date Printed: 05/05/2022
Work Order #: 2203-03920
Client Job #: 609
Date Received: 03/29/2022
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche
Laboratory Director

A & L Laboratory: Accreditations: Maine ME00021, New Hampshire 2501, Maine Radon Registration ID # SPC20
Granite State Analytical Services, LLC: Accreditations: New Hampshire 1015; Maine NH00003;
Massachusetts M-NH0003; Rhode Island 101513; Vermont VT-101507
Nashoba Analytical, LLC: Accreditations: Massachusetts M-MA1118



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
 Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 05/05/2022
CLIENT NAME: Mt Blue High School
CLIENT ADDRESS: 129 Seamon Rd
 Farmington, ME 04938
METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

DATE AND TIME RECEIVED: 03/29/2022 01:05PM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 16° CELSIUS
CLIENT JOB #: 609

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2203-03920-001	bottle fill outside B123	I	DWF	03/26/2022 06:40AM	<1	ppb			DR-NH	05/04/2022 08:43PM
2203-03920-002	bottle fill outside B225	I	DWF	03/26/2022 06:40AM	<1	ppb			DR-NH	05/04/2022 08:46PM
2203-03920-003	bottle fill outside B321	I	DWF	03/26/2022 06:40AM	<1	ppb			DR-NH	05/04/2022 08:49PM
2203-03920-004	teachers lounge sink B303	I	OT	03/26/2022 06:40AM	3.2	ppb			DR-NH	05/04/2022 09:01PM
2203-03920-005	buisness office sink A234	I	OT	03/26/2022 06:34AM	2.3	ppb			DR-NH	05/04/2022 09:04PM
2203-03920-006	bottle fill outside D134	I	DWF	03/26/2022 06:32AM	<1	ppb			DR-NH	05/04/2022 09:06PM
2203-03920-007	bottle fill outside A130	I	DWF	03/26/2022 06:42AM	<1	ppb			DR-NH	05/04/2022 09:09PM
2203-03920-008	bottle fill outside E107	I	DWF	03/26/2022 06:35AM	<1	ppb			DR-NH	05/04/2022 09:12PM
2203-03920-009	sink room E101	I	OT	03/26/2022 06:35AM	2.4	ppb			DR-NH	05/04/2022 09:15PM
2203-03920-010	bottle fill outside F117	I	DWF	03/26/2022 06:47AM	<1	ppb			DR-NH	05/04/2022 09:24PM
2203-03920-011	bottle fill outside F223	I	DWF	03/26/2022 06:49AM	<1	ppb			DR-NH	05/04/2022 09:27PM
2203-03920-012	teachers lounge sink F200	I	OT	03/26/2022 06:46AM	2.1	ppb			DR-NH	05/04/2022 09:36PM
2203-03920-013	coaches sink C134	I	OT	03/26/2022 06:43AM	6.7	ppb			DR-NH	05/04/2022 09:39PM
2203-03920-014	kitchen kettle C101	I	KF	03/26/2022 06:45AM	6.6	ppb			DR-NH	05/04/2022 09:42PM
2203-03920-015	kitchen double sink C101	I	KF	03/26/2022 06:43AM	2.2	ppb			DR-NH	05/04/2022 09:45PM
2203-03920-016	kitchen hand sink C101	I	KF	03/26/2022 06:43AM	1.3	ppb			DR-NH	05/04/2022 09:48PM
2203-03920-017	kitchen hand sink #2 C101	I	KF	03/26/2022 06:45AM	4.4	ppb			DR-NH	05/04/2022 09:50PM
2203-03920-018	nurse's sink A156	I	OT	03/26/2022 06:42AM	2.5	ppb			DR-NH	05/04/2022 09:53PM
2203-03920-019	home economics sink #1 F110	I	OT	03/26/2022 06:47AM	3.7	ppb			DR-NH	05/04/2022 09:56PM
2203-03920-020	home economics sink #2 F110	I	OT	03/26/2022 06:47AM	1.4	ppb			DR-NH	05/04/2022 10:14PM
2203-03920-021	home economics sink #3 F110	I	OT	03/26/2022 06:46AM	1.8	ppb			DR-NH	05/04/2022 10:17PM

Rebecca L. Labranche
 Laboratory Director