

A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210 Phone (207) 784-5354 website www.allaboratory.com

Laboratory Report

Mt Blue Middle School 269 Middle St Farmington, ME 04938 Date Printed: 05/05/2022
Work Order #: 2203-03915
Client Job #: 608
Date Received: 03/29/2022
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:

Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratorv.com

Granite State Analytical Services LLC:

Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. None
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample.
 These are indicated under the DQ Flags Column on your report and listed here if necessary: Data Qualifier (DQ) Flags: None

SAMPLE STATE SPECIFIC NOTES:

 The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: None

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES. LLC.

155 Center Street, Building C, Auburn, Maine 04210 Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED:

05/05/2022

CLIENT NAME:

Mt Blue Middle School

CLIENT ADDRESS:

REPORTING LIMIT:

269 Middle St

1 ppb

Farmington, ME 04938

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb

Legend Lead Above 4 ppb Lead Above 15 ppb

⊕ ⊗

DATE AND TIME RECEIVED: ANALYSIS PACKAGE: 03/29/2022 01:05PM Maine Schools-Lead

RECEIPT TEMPERATURE: 17° CELSIUS

CLIENT JOB #: 608

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2203-03915-001	bottle fill outside office	1	DWF	03/26/2022 07:34AM	<1	ppb			DR-NH	05/04/2022 04:31PM
2203-03915-002	sink room 9	V I	OT	03/26/2022 07:38AM	2.4	ppb			DR-NH	05/04/2022 04:34PM
2203-03915-003	sink staff room by gym	- 1	OT	03/26/2022 07:34AM	12.8	ppb	1		DR-NH	05/04/2022 04:43PM
2203-03915-004	water fountain #1 outside gym	1	DWF	03/26/2022 07:34AM	1.1	ppb			DR-NH	05/04/2022 04:46PM
2203-03915-005	water fountain #2 outside gym	I	DWF	03/26/2022 07:34AM	1.0	рpb			DR-NH	05/04/2022 04:48PM
2203-03915-006	bottle fill outside gym	- 1 -	DWF	03/26/2022 07:34AM	1.5	ppb			DR-NH	05/04/2022 04:51PM
2203-03915-007	sink nurse's room	1	OT	03/26/2022 07:38AM	2.4	ppb			DR-NH	05/04/2022 05:00PM
2203-03915-008	bottle fill b-wing	1	DWF	03/26/2022 07:35AM	<1	ppb			DR-NH	05/04/2022 05:03PM
2203-03915-009	sink staff lounge A-wing	1	OT	03/26/2022 07:36AM	2.3	ppb			DR-NH	05/04/2022 05:06PM
2203-03915-010	waterfountain outside cafe	1	DWF	03/26/2022 07:36AM	<1	ppb			DR-NH	05/04/2022 05:09PM
2203-03915-011	bottle fill outside cafe	1	DWF	03/26/2022 07:36AM	<1	ppb			DR-NH	05/04/2022 05:21PM
2203-03915-012	kitchen kettle	1	KF	03/26/2022 07:40AM	1.7	ppb			DR-NH	05/04/2022 05:24PM
2203-03915-013	kitchen hand sink #1	1	KF	03/26/2022 07:40AM	7.2	ppb	1		DR-NH	05/04/2022 05:27PM
2203-03915-014	kitchen hand sink #2	1	KF	03/26/2022 07:40AM	5.6	ppb	1		DR-NH	05/04/2022 05:29PM
2203-03915-015	kitchen dish sink	1	KF	03/26/2022 07:40AM	2.6	ppb			DR-NH	05/04/2022 05:32PM
2203-03915-016	sink room W	1	OT	03/26/2022 07:39AM	3.8	ppb			DR-NH	05/04/2022 05:35PM

Rebecca L. Labranche Laboratory Director

ZIILL

Page 2 of 2