



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

Laboratory Report

Cascade Brook School
162 Learning Ln
Farmington, ME 04938

Date Printed: 07/25/2022
Work Order #: 2205-03581
Client Job #: 610
Date Received: 05/21/2022
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche
Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
 Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 07/25/2022
CLIENT NAME: Cascade Brook School

CLIENT ADDRESS: 162 Learning Ln
 Farmington, ME 04938

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

DATE AND TIME RECEIVED: 05/21/2022 06:25AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 19° CELSIUS
CLIENT JOB #: 610

| Legend | |
|-------------------|--|
| Lead Above 4 ppb | |
| Lead Above 15 ppb | |

| Sample ID # | Location | Sample Type | Outlet Type | Date - Time Water Sampled | Result | Test Units | Pass /Fail | DQ Flag | Analyst | Date - Time Analyzed |
|----------------|--------------------|-------------|-------------|---------------------------|--------|------------|------------|---------|---------|----------------------|
| 2205-03581-001 | kitchen kettle | F | KF | 05/20/2022 06:27AM | <1 | ppb | | | DG-NH | 07/23/2022 12:04AM |
| 2205-03581-002 | kitchen 3-bay sink | F | KF | 05/20/2022 06:24AM | <1 | ppb | | | DG-NH | 07/23/2022 12:08AM |
| 2205-03581-003 | kitchen hand sink | F | KF | 05/20/2022 06:30AM | 16.0 | ppb | | | DG-NH | 07/23/2022 12:11AM |
| 2205-03581-004 | kitchen sink | F | KF | 05/20/2022 06:21AM | 1.7 | ppb | | | DG-NH | 07/23/2022 12:26AM |

Rebecca L. Labranche
 Laboratory Director