



# A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210  
Phone (207) 784-5354 website [www.allaboratory.com](http://www.allaboratory.com)

## Laboratory Report

**Mt Blue High School**  
129 Seamon Rd  
Farmington, ME 04938

**Date Printed:** 07/25/2022  
**Work Order #:** 2205-02810  
**Client Job #:** 609  
**Date Received:** 05/18/2022  
**Sample collected in:** Maine

**Attached please find results for the analysis of the samples received on the date referenced above.**

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the \* symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

**A & L Laboratory:**  
*Identified by ME in Analyst Column*  
155 Center Street, Auburn, Maine 04210  
[www.allaboratory.com](http://www.allaboratory.com)

**Granite State Analytical Services LLC:**  
*Identified by NH in Analyst Column*  
22 Manchester Road, Derry, NH 03038  
[www.granitestateanalytical.com](http://www.granitestateanalytical.com)

### ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

### SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche  
Laboratory Director



# A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210  
 Phone (207) 784-5354 website www.allaboratory.com

## CERTIFICATE OF ANALYSIS FOR DRINKING WATER

**DATE PRINTED:** 07/25/2022  
**CLIENT NAME:** Mt Blue High School

**CLIENT ADDRESS:** 129 Seamon Rd  
 Farmington, ME 04938

**METHOD:** EPA 200.8  
**EPA ACTION LEVEL:** 15 ppb  
**MAINE GUIDELINE:** 4 ppb  
**REPORTING LIMIT:** 1 ppb

**DATE AND TIME RECEIVED:** 05/18/2022 07:30AM  
**ANALYSIS PACKAGE:** Maine Schools-Lead  
**RECEIPT TEMPERATURE:** 21° CELSIUS  
**CLIENT JOB #:** 609

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2205-02810-001	coaches sink C134	C	OT	05/16/2022 06:38AM	<1	ppb			DR-NH	07/20/2022 07:34PM
2205-02810-002	kitchen kettle C101	C	KF	05/16/2022 06:34AM	1.4	ppb			DR-NH	07/20/2022 07:37PM
2205-02810-003	kitchen hand sink #2 C101	C	KF	05/16/2022 06:32AM	45.3	ppb			DR-NH	07/22/2022 07:13PM

Rebecca L. Labranche  
 Laboratory Director