

School	Location	Initial Result	Confirmation Result	Flush Result	Consultant Recommendations
AHS	Bottle Fill Outside Office	6.4	8.7	9.7	Replace fixture and cooler and re-test - tag for no use
AHS	Nurses Room Sink	16.9	1.3	<1	Ok to use
AHS	Sink Room 211	83.3	40.7	13.8	Replace fixture and cooler and re-test - tag for no use
AHS	Bottle Fill Ground Floor	14.2	7.2	3.6	Replace fixture and retest - tag for no use
AHS	Kitchen Kettle #1	22.2	<1	<1	Ok to use
AHS	Kitchen Kettle #2	8.6	<1	<1	Ok to use
AHS	Kitchen Food Prep	6.1	<1	<1	Ok to use
AHS	Kitchen Dish Prep	5.7	3.5	3	Retest for minimum of 8 hours hold time - tag for no use
School Start Status					
Bottled Water for Students and Staff					
Kitchen sinks use permits regular Kitchen operation					
CBS	Kitchen Kettle	25.6	1	<1	Ok to use
CBS	Kitchen 3 Bay Sink	29.3	<1	<1	Ok to use
CBS	Kitchen Hand Sink	17.4	21.7	16	Replace fixture and look at lead joints and solder behind it. - tag for no use
CBS	Kitchen Sink	11.3	1.4	1.7	Ok to use
CBS	Sink Room 112	4.2	42.6	7.6	Replace fixture and look at lead joints and solder behind it. - tag for no use
CBS	Sink Room 117	9.3	7.8	24.8	Replace fixture and look at lead joints and solder behind it. - tag for no use
CBS	Sink Room 250	15.2	9.3	2.8	Replace fixture and retest - tag for no use
CBS	Sink Room 253	12.6	2.6	4.8	Replace fixture and look at lead joints and solder behind it. - tag for no use
CBS	Sink Room 254	6	<1	<1	Ok to use
CBS	Sink Room 255	14.9	2.6	2.6	Ok to use
CBS	Sink Room 240	10.4	8.5	<1	Replace fixture and retest - tag for no use
CBS	Sink Room 244	13.4	4.1	3.2	Replace fixture and retest - tag for no use
CBS	Sink Room 245	14.7	11	1.3	Replace fixture and retest - tag for no use
CBS	Sink Room 260	19.4	25.9	3.5	Replace fixture and retest - tag for no use
CBS	Sink Room 261	12.1	13.5	1.6	Replace fixture and retest - tag for no use
CBS	Sink Room 204	15.4	20.4	1.5	Replace fixture and retest - tag for no use
CBS	Sink Room 264	17.6	44.4	3.2	Replace fixture and retest - tag for no use
CBS	Sink Room 265	17.1	11.9	1.8	Replace fixture and retest - tag for no use
School Start Status					
Student and Staff may consume from designated faucets					
Kitchen sinks use permits regular Kitchen operation					
CCHS	Kitchen Kettle	8.7	<1	<1	Ok to use

CCHS	Sink Nurse's Room	6	627	2.4	Replace fixture and retest - tag for no use
CCHS	Sink Room 104	5.4	141	9.4	Replace fixture and look at lead joints and solder behind it. - tag for no use
CCHS	Sink Room 103	6.7	994	8.1	Replace fixture and look at lead joints and solder behind it. - tag for no use
CCHS	Sink Room 106	5.2	24.4	8.6	Replace fixture and look at lead joints and solder behind it. - tag for no use
CCHS	Sink Room 204	13.9	18.5	2.3	Replace fixture and retest - tag for no use
CCHS	Sink Room 202	7.8	1.4	3.7	Replace fixture and retest - tag for no use
CCHS	Sink Room 203	13.8	2.3	1.6	Ok to use
CCHS	Sink Room 205	15.8	4.8	2.1	Replace fixture and retest - tag for no use
CCHS	Sink Room 206	11.3	<1	<1	Ok to use
School Start Status					
Student and Staff may consume from designated faucets					
Kitchen sinks use permits regular Kitchen operation					
GDC	Kitchen Sink	27.1	2.3	1.6	Retest for minimum of 8 hours hold time - tag for no use
GDC	Sink Pre-K	8	<1	3.3	Retest for minimum of 8 hours hold time - tag for no use
GDC	Sink Room 30	5.3	2	17.3	Replace fixture and look at lead joints and solder behind it. - tag for no use
School Start Status					
Student and Staff may consume from designated faucets					
Kitchen can operate with one available sink and water from AHS for food prep					
MBHS	Coach's Sink Room 134	6.7	<1	<1	Ok to use
MBHS	Kitchen Kettle C101	6.6	1.4	<1	Ok to use
MBHS	Kitchen Hand Sink #2	4.4	45.3	13.6	Replace fixture and look at lead joints and solder behind it. - tag for no use
School Start Status					
Student and Staff may consume from designated faucets					
Kitchen sinks use permits regular Kitchen operation					
MBMS	Sink Staff Room by Gym	12.8	1.8	<1	Ok to use
MBMS	Kitchen Hand Sink #1	7.2	1.2	<1	Ok to use
MBMS	Kitchen Hand Sink #2	5.6	14.6	15.4	Replace fixture and look at lead joints and solder behind it. - tag for no use
School Start Status					
Student and Staff may consume from designated faucets					
Kitchen sinks use permits regular Kitchen operation					
WGM	Sink Nurse's Room	5.2	5.3	4.3	Replace fixture and look at lead joints and solder behind it. - tag for no use
WGM	Sink Teacher's Lounge	4.1	166	8.3	Replace fixture and look at lead joints and solder behind it. - tag for no use

WGM	Kitchen Kettle	124	7.4	4.3	Replace fixture and look at lead joints and solder behind it. - tag for no use
WGM	Kitchen Hand Sink	4.4	85.6	32	Replace fixture and look at lead joints and solder behind it. - tag for no use
WGM	Kitchen 3-Bay Sink	21.2	37.7	3.8	Replace fixture and look at lead joints and solder behind it. - tag for no use
WGM	Kitchen Dish Sink	23.1	9.8	1.5	Replace fixture and look at lead joints and solder behind it. - tag for no use
WGM	Sink Room 114	5.5	<1	2.3	Ok to use
WGM	Sink Room 222	4.2	186	4.3	Replace fixture and look at lead joints and solder behind it. - tag for no use
WGM	Sink Room 219	4.5	388	5.1	Replace fixture and look at lead joints and solder behind it. - tag for no use
School Start Status					
Bottle Water will be provided for students and staff while further remediation work is completed.					
Bottled Water will be used for Kitchen Operations					
General Comments and observations					
Re-testing of fixtures listed above seeks a result of < 4 ppb from a "standing water" test					
Fixtures noted above as "tag for no use" may not be used for consumption but may be used to wash hands					
Sample bottles have been ordered for the next round of retesting					
Please keep signage up in schools on faucets "not to be used for consumption" and not for use if on this list					
Consumption based fixtures that tested below 4 ppb on the initial testing results and as "ok to use on the above list do not need sign					