



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

Laboratory Report

Mt Blue High School
129 Seamon Rd
Farmington, ME 04938

Date Printed: 03/21/2023
Work Order #: 2303-02572
Client Job #: 609
Date Received: 03/16/2023
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

Nashoba Analytical:
Identified by MA in the Analyst Column
31A Willow Road, Ayer, MA 01432
www.nashobaanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- DF: "Dilution factor" means the ratio of the volume of the sample to the volume of the final (dilute) solution.
- MDL: "Minimum Detection Limit" means the minimum result which can be reliably discriminated from a blank with a predetermined confidence level.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche
Laboratory Director

A & L Laboratory: Accreditations: Maine ME00021, New Hampshire 2501, Maine Radon Registration ID # SPC20
Granite State Analytical Services, LLC: Accreditations: New Hampshire 1015; Maine NH00003;
Massachusetts M-NH0003; Rhode Island 101513; Vermont VT-101507
Nashoba Analytical: Accreditations: Massachusetts M-MA1118



A & L LABORATORY



A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
 Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 03/21/2023
CLIENT NAME: Mt Blue High School

CLIENT ADDRESS: 129 Seamon Rd
 Farmington, ME 04938

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

DATE AND TIME RECEIVED: 03/16/2023 06:45AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 18° CELSIUS
CLIENT JOB #: 609

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2303-02572-001	kitchen hand sink #2 C101	P	KF	03/15/2023 10:31AM	3.0	ppb			DG-NH	03/20/2023 02:52PM



Rebecca L. Labranche
 Laboratory Director