

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210 Phone (207) 784-5354 website www.allaboratory.com

Laboratory Report

W G Mallett School 116 Middle Street Farmington, ME 04938 Date Printed: 03/21/2023
Work Order #: 2303-02580
Client Job #: 607
Date Received: 03/16/2023
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:

Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:

Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

Nashoba Analytical:

Identified by MA in the Analyst Column 31A Willow Road, Ayer, MA 01432 www.nashobaanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- DF: "Dilution factor" means the ratio of the volume of the sample to the volume of the final (dilute) solution.
- MDL: "Minimum Detection Limit" means the minimum result which can be reliably discriminated from a blank with a predetermined confidence level.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for
 each analyte and the appropriate laboratory will be listed here. None
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample.
 These are indicated under the DQ Flags Column on your report and listed here if necessary: Data Qualifier (DQ) Flags: None

SAMPLE STATE SPECIFIC NOTES:

• The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: None

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.



A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210 Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED:

03/21/2023

CLIENT NAME:

W G Mallett School

CLIENT ADDRESS:

116 Middle Street

Farmington, ME 04938

METHOD: EPA 200.8 EPA ACTION LEVEL: MAINE GUIDELINE:

15 ppb 4 ppb

REPORTING LIMIT: 1 ppb Legend

Lead Above 4 ppb Lead Above 15 ppb



DATE AND TIME RECEIVED: **ANALYSIS PACKAGE:**

03/16/2023 07:30AM

Maine Schools-Lead


RECEIPT TEMPERATURE:

17° CELSIUS

CLIENT JOB #:

607

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units Pass DQ /Fail Flag	Analyst	Date - Time Analyzed
2303-02580-001	sink nurse's room	Р	OT	03/15/2023 06:56AM	<1	ppb	DG-NH	03/20/2023 04:26PM
2303-02580-002	sink teachers lounge	Р	OT	03/15/2023 07:03AM	<1	ppb	DG-NH	03/20/2023 04:29PM
2303-02580-003	kitchen kettle	Р	KF	03/15/2023 07:08AM	1.9	ppb	DG-NH	03/20/2023 04:40PM
2303-02580-004	kitchen hand sink	Р	KF	03/15/2023 07:13AM	2.0	ppb	DG-NH	03/20/2023 04:44PM
2303-02580-005	kitchen 3-bay sink	Р	KF	03/15/2023 07:30AM	<1	ppb	DG-NH	03/20/2023 04:47PM
2303-02580-006	kitchen dish sink	Р	KF	03/15/2023 07:27AM	<1	ppb	DG-NH	03/20/2023 04:51PM
2303-02580-007	sink room 114	Р	ОТ	03/15/2023 07:08AM	<1	ppb	DG-NH	03/20/2023 05:02PM
2303-02580-008	sink room 222	Р	OT	03/15/2023 07:20AM	2.1	ppb	DG-NH	03/20/2023 05:05PM
2303-02580-009	sink room 219	Р	ОТ	03/15/2023 07:22AM	<1	ppb	DG-NH	03/20/2023 05:09PM



A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210 Phone (207) 784-5354 website www.allaboratory.com

Laboratory Report

W G Mallett School 116 Middle Street Farmington, ME 04938 Date Printed: 03/21/2023
Work Order #: 2303-02585
Client Job #: 607
Date Received: 03/16/2023
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:

Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:

Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

Nashoba Analytical:

Identified by MA in the Analyst Column 31A Willow Road, Ayer, MA 01432 www.nashobaanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- DF: "Dilution factor" means the ratio of the volume of the sample to the volume of the final (dilute) solution.
- MDL: "Minimum Detection Limit" means the minimum result which can be reliably discriminated from a blank with a predetermined confidence level.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for
 each analyte and the appropriate laboratory will be listed here. None
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample.
 These are indicated under the DQ Flags Column on your report and listed here if necessary: Data Qualifier (DQ) Flags: None

SAMPLE STATE SPECIFIC NOTES:

• The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: None

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.



A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210 Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

Date - Time

Water Sampled

DATE PRINTED:

03/21/2023

CLIENT NAME:

W G Mallett School

CLIENT ADDRESS:

116 Middle Street

Farmington, ME 04938

METHOD: EPA ACTION LEVEL:

EPA 200.8 15 ppb

MAINE GUIDELINE:

Sample ID #

4 ppb

REPORTING LIMIT: 1 ppb

2303-02585-001 Supply Line

Location

ocation.

Sample Outlet Type Type

S 03/15/2023 06:56AM

<1

ppb

CLIENT JOB #:

Result Test Units Pass DQ

Legend

Lead Above 4 ppb Lead Above 15 ppb

Š

DATE AND TIME RECEIVED: 03/16/2023 07:30AM

ANALYSIS PACKAGE: Maine Schools-Lead

RECEIPT TEMPERATURE: 17° CELSIUS

/Fail Flag

607

Analyst Date - Time Analyzed

DG-NH 03/20/2023 05:12PM

Z11hh